

Confirmation

LEED

On 25 July 2014, Eurofins Product Testing A/S received a sample of an adhesive with the product name:

HIT-HY 270

supplied by

Hilti Entwicklungsgesellschaft GmbH

The sample was supplied as being representative of the manufactured product, and it has been tested as multipurpose construction adhesive in accordance with the relevant, ISO 11890-1, ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2014-00149701rev1).

The test results of the tested adhesive indicate that the product qualifies for LEED 2009 specifications VOC content by complying with:

VOC content specifications in LEED EQ credit "Low-emitting products":

- the requirements of SCAQMD rule 1168 (2005)

6 October 2014



Maria Pelle
Chemist



Søren Ryom Villadsen
Analytical Service Manager